

**City of Mt. Juliet  
Department of Engineering  
Report of Submittal Review**

**Date Received: April 06, 2026 (March 24, 2026)**  
**Project Name: Providence Central – West (7100 Central Pike)**  
**Project Phase: Mass Grading**  
**Submitted By: Heritage Civil**

**Nature of Submittal:**

- Preliminary Plat                       Final Plat                       Site Plan  
 PMDP     FMDP – Mass Grading                       Construction Plans

**Engineering Comments:**

1. Drainage report under preliminary review. A comprehensive review of the drainage report shall take place at construction plan review.
2. The development shall grade a segment of the proposed public road connecting the extension of Providence Parkway and John Hagar Road. This segment shall run between Providence Parkway and the stream buffer to the north. A viable alignment, compliant with City standards and federal guidelines, must be approved by the Director of Engineering prior to issuance of the Land Disturbance Permit.

**WWUD Comments:**

1. No Comments. This is in Gladeville’s service area.

**Recommendation: Approve with conditions**  
**Review Date: April 09, 2026 (March 26, 2026)**  
**Reviewed By: Shane Shamanur, P.E.**  
**Engineering – Director**  
**City of Mt. Juliet**  
**(615) 773-7957**

**Note: Review of this submittal does not relieve the Developer and Consultant from full compliance with the requirements of the Subdivision Regulations for the Mt. Juliet Regional Planning Commission and/or from full compliance with the requirements of the Zoning Ordinance for the City of Mt. Juliet**