

## Jake Porter

---

**From:** Brent Blamires <bblamires@mtjuliet-tn.gov>  
**Sent:** Thursday, August 22, 2024 9:23 AM  
**To:** Jake Porter  
**Subject:** RE: Elliott Reserve

Yes, with them being brick and sprinkled 20' is acceptable to me.

Thank you,



### **Brent Blamires**

Chief of Prevention/Fire Marshal  
Fire Department | City of Mt. Juliet, TN

---

SERVICE – DEDICATION - EXCELLENCE

Office 615-773-9864 | Mobile 629-250-9969

bblamires@mtjuliet-tn.gov

<https://www.mtjuliet-tn.gov/>

115 Clemmons Rd. Mt. Juliet, Tennessee 37122

**CONFIDENTIALITY NOTICE:** *This e-mail, including any attachments, may contain confidential information which is intended only for the use of the individual(s) or entitled named. If you receive this e-mail message in error, please immediately notify the sender by e-mail and delete it. Dissemination, forwarding, printing or copying of this e-mail without prior consent of the sender is strictly prohibited.*

*Thank you for your compliance.*

---

**From:** Jake Porter <JakeP@csdgt.com>  
**Sent:** Thursday, August 22, 2024 9:09 AM  
**To:** Brent Blamires <bblamires@mtjuliet-tn.gov>  
**Subject:** Re: Elliott Reserve

Yessir they are brick

Jake Porter, PE  
CSDG

---

**From:** Brent Blamires <[bblamires@mtjuliet-tn.gov](mailto:bblamires@mtjuliet-tn.gov)>  
**Sent:** Thursday, August 22, 2024 8:56:18 AM  
**To:** Jake Porter <[JakeP@csdgtn.com](mailto:JakeP@csdgtn.com)>  
**Subject:** RE: Elliott Reserve

Will the townhomes have brick siding?



**Brent Blamires**

Chief of Prevention/Fire Marshal  
Fire Department | City of Mt. Juliet, TN

---

SERVICE – DEDICATION - EXCELLENCE

Office 615-773-9864 | Mobile 629-250-9969

[bblamires@mtjuliet-tn.gov](mailto:bblamires@mtjuliet-tn.gov)

<https://www.mtjuliet-tn.gov/>

115 Clemmons Rd. Mt. Juliet, Tennessee 37122

**CONFIDENTIALITY NOTICE:** *This e-mail, including any attachments, may contain confidential information which is intended only for the use of the individual(s) or entitled named. If you receive this e-mail message in error, please immediately notify the sender by e-mail and delete it. Dissemination, forwarding, printing or copying of this e-mail without prior consent of the sender is strictly prohibited. Thank you for your compliance.*

---

**From:** Jake Porter <[JakeP@csdgtn.com](mailto:JakeP@csdgtn.com)>  
**Sent:** Thursday, August 22, 2024 8:19 AM  
**To:** Brent Blamires <[bblamires@mtjuliet-tn.gov](mailto:bblamires@mtjuliet-tn.gov)>  
**Subject:** Elliott Reserve

Good morning, Brent,

Hope you are doing well today!

I have a Preliminary Master Development Plan going through MJ Planning and BOC right now and have been asked to confirm with you that we can space the townhomes 20' apart if we auto sprinkler them. Can you please confirm that this is acceptable? Feel free to give me a call if you have any questions.

Thank you!

**Jake Porter, PE**

*Associate • Professional Engineer*



## **CSDG**

Planning | Engineering | Landscape Architecture

2305 Kline Avenue, Suite 300

Nashville, Tennessee 37211

615.248.9999 *office*

[jakep@csdgtm.com](mailto:jakep@csdgtm.com)

[csdgtm.com](http://csdgtm.com)